

Clarification Questions

Tender:	LGM3899 Medical Gases
Date:	10-03-26
Client:	UHMB

No.	Question
1.	<p>The specification states: <i>“Annually, a non-invasive test must be carried out on 25% of all pressure-related alarms.”</i></p> <p>Given that alarm testing can vary significantly and is difficult to cost accurately, this work is often priced on a <i>day-rate</i> basis.</p> <p>Can we propose a day-rate approach for this contract?</p>
	<p>Response</p> <p>Yes. The Authority has reviewed the request and agrees that this activity may be costed on a day-rate basis. A corresponding section has been added to the <i>ad hoc</i> area of the pricing schedule for each site, and a new version has been uploaded to the portal. Please ensure you use the updated pricing schedule when preparing your tender submission.</p> <p><i>‘Please provide a day rate for assisting the Trust AP’s to carry out tests on the correct operation of pressure switches on local alarm panels’</i></p> <p>The Technical Specification has been updated to reflect this change.</p>

No.	Question
2.	<p>Would you be able to check that all required documentation is attached? We can only see Schedule 5, 6 and 7 on the portal.</p>
	<p>Response</p> <p>The following documents are available on the portal:</p> <ol style="list-style-type: none"> 1. ITT 2. Schedule 5 - Technical Specification 3. Schedule 6 - Pricing Schedule 4. Schedule 7 - PSQ

5. Appendix A - Equipment Schedule

Invitation to Tender

ITT Start Date	27 Feb 26	ITT Close Date	24 Mar 26 14:00
ITT Documents	LGM38199 Medical Gases Appendix A Site Equipment Schedules V2.xlsx LGM38199 Medical Gases PA23 Open ITT V1.0 LB 2026-02-27.docx Schedule 5 LGM38199 Medical Gases TechSpec V1.0 LB 2026-02-27.pdf Schedule 6 LGM38199 Medical Gases Pricing V1.0 LB 2026-02-27.xlsx Schedule 7 LGM38199 Medical Gases PA23 - PSQ V1.0 LB 2026-02-27.docx		

Please note: the version numbers have been updated since this screen shot was taken.

If you do not have access to all documents, please send a screen shot of what you can see as a clarification and it will be investigated.

No.	Question
	Please can we request an editable version of the ITT questionnaire
3.	Response
	The current ITT has editable sections for all areas that require editing. An unprotected version of the ITT has also been uploaded to the portal - V2.